

## What are we testing for?

### Our standard onsite water test analyses for the following:

- Free chlorine
- Total chlorine
- Chloride
- Exact pH level
- Exact temperature
- Water hardness
- Iron check
- Alkalinity
- Conductivity
- Nitrate
- Nitrite
- Hydrogen sulphide
- Sulphate
- Copper
- Ammonia
- Silver hydrogen peroxide



Testing for Coliforms and E. coli requires a 24 hour incubation period at 35 degrees.

### Laboratory testing is required for the below:

- Bacteria – up to 3 days for the results
- Pseudomonas species – up to 3 days for the results
- Phosphate – up to 3 days for the results
- Legionella – up to 10 days for the results, 12 if there is a growth



WTG – APR 2017

